

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W22 NEMA Premium Efficiency Three-Phase

Product code : 16832332

Catalog # : 00718ET3E213TC-W22G

Frame : 213/5TC
 Output : 7.5 HP (5.5 kW)
 Poles : 4
 Frequency : 60 Hz
 Rated voltage : 230/460 V
 Rated current : 18.4/9.18 A
 L. R. Amperes : 130/65.2 A
 LRC : 7.1x(Code H)
 No load current : 8.40/4.20 A
 Rated speed : 1765 rpm
 Slip : 1.94 %
 Rated torque : 22.3 ft.lb
 Locked rotor torque : 220 %
 Breakdown torque : 310 %
 Insulation class : F
 Service factor : 1.25
 Moment of inertia (J) : 1.34 sq.ft.lb
 Design : B

Locked rotor time : 36s (cold) 20s (hot)
 Temperature rise : 80 K
 Duty cycle : Cont.(S1)
 Ambient temperature : -20°C to +40°C
 Altitude : 1000 m.a.s.l.
 Protection degree : IP55
 Cooling method : IC411 - TEFC
 Mounting : F-1
 Rotation¹ : Both (CW and CCW)
 Noise level² : 58.0 dB(A)
 Starting method : Direct On Line
 Approx. weight³ : 171 lb

Output	25%		50%		75%		100%	
Efficiency (%)	88.6	89.2	89.5	89.5	91.0	89.5	91.7	89.6
	89.2	89.3	89.5	89.5	90.2	90.2	90.2	90.2
Power Factor	0.40	0.47	0.66	0.72	0.76	0.81	0.82	0.85
	0.43	0.40	0.69	0.66	0.78	0.76	0.83	0.82

Foundation loads
 Max. traction : 354 lb
 Max. compression : 525 lb

Losses at normative operating points (speed;torque), in percentage of rated output power

Losses (%)	P1 (0,9;1,0)	8.8	8.8	8.8	8.8
	P2 (0,5;1,0)	7.0	7.0	7.0	7.0
	P3 (0,25;1,0)	6.5	6.5	6.5	6.5
	P4 (0,9;0,5)	4.9	4.9	4.9	4.9
	P5 (0,5;0,5)	3.3	3.3	3.3	3.3
	P6 (0,5;0,25)	2.4	2.4	2.4	2.4
	P7 (0,25;0,25)	1.6	1.6	1.6	1.6

		<u>Drive end</u>	<u>Non drive end</u>
Bearing type	:	6308 ZZ	6207 ZZ
Sealing	:	V'Ring	V'Ring
Lubrication interval	:	-	-
Lubricant amount	:	-	-
Lubricant type	:	Mobil Polyrex EM	

Notes:

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary	Performed	Checked	Date
Performed by				
Checked by				
Date	26/03/2024			

Page 1 / 1
 Revision