## **DATA SHEET**

## Three Phase Induction Motor - Squirrel Cage



| Customer   |                     | :  |                     |              |   |   |
|--|---------------------|--|---------------------|--------------|---|---|
| Product line : W22 Standard Efficiency   |                     |  |                     | / Three-Pha  | ase Product code :<br>Catalog # :   | 12683838<br>00512ES3EOW215T-W22   |
| Frame Output Poles Frequency Rated voltage Rated current L. R. Amperes LRC No load current Rated speed Slip Rated torque Locked rotor torque Breakdown torque Insulation class Service factor Moment of inertia (J) Design |                     | : 213/5T<br>: 5 HP (3.7 kW)<br>: 6<br>: 60 Hz<br>: 208-230/460 V<br>: 17.1-15.5/7.73 A<br>: 106-95.9/47.9 A<br>: 6.2x(Code J)<br>: 9.24-8.36/4.18 A<br>: 1060 rpm<br>: 11.67 %<br>: 24.8 ft.lb<br>: 380 %<br>: 0 %<br>: F<br>: 1.15<br>: 1.16 sq.ft.lb |                     |              | Locked rotor time Temperature rise Duty cycle Ambient temperature Altitude Protection degree Cooling method Mounting Rotation¹ Noise level² Starting method Approx. weight³ | : 45s (cold) 25s (hot) : 80 K : Cont.(S1) : -20°C to +40°C : 1000 m.a.s.l. : IP55 : IC411 - TEFC : F-2 : Both (CW and CCW) : 55.0 dB(A) : Direct On Line : 178 lb |
| Output Efficiency (%) Power Factor   | 25%<br>77.4<br>0.34 | 50%<br>77.0<br>0.58  | 75%<br>78.5<br>0.70 | 77.0<br>0.78 | Foundation loads Max. traction Max. compression   | : -89 lb<br>: 89 lb   |
| Bearing type : 6308 ZZ Sealing : V'Ring Lubrication interval : - Lubricant amount : - Lubricant type : Mo  |                     | Non drive end 6207 ZZ V'Ring   |                     |              |   |   |

Notes:

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

| Rev.         |            | Changes Summary | Performed | Checked | Date     |
|--------------|------------|-----------------|-----------|---------|----------|
|              |            |                 |           |         |          |
| Performed by |            |                 |           |         |          |
| Checked by   |            |                 |           | Page    | Revision |
| Date         | 26/03/2024 |                 |           | 1/1     |          |