## **DATA SHEET**



Three Phase	induction ivio	tor - Squirrei	Cage			
Customer	:					
Product line	: W22 IEEE 841 NEMA Premium Effici Three-Phase		ency Product cod		14325714 35018ST3QIERB449T-W2	
Frame Output Poles Frequency Rated voltage Rated current L. R. Amperes LRC No load current Rated speed Slip Rated torque Locked rotor torque Breakdown torque Insulation class Service factor Moment of inertia (J	Output : 350 HP (260 kW)  Poles : 4  Frequency : 60 Hz  Rated voltage : 460 V  Rated current : 394 A  L. R. Amperes : 2719 A  LRC : 6.9x(Code G)  No load current : 115 A  Rated speed : 1787 rpm  Slip : 0.72 %  Rated torque : 1030 ft.lb  Locked rotor torque : 260 %  Breakdown torque : 229 %  Insulation class : F  Service factor : 1.15  Moment of inertia (J) : 131 sq.ft.lb		Locked rotor time  Temperature rise  Duty cycle  Ambient temperature  Altitude  Protection degree  Cooling method  Mounting  Rotation¹  Noise level²  Starting method  Approx. weight³  Starting starting starting method  Approx. weight³  Starting starting method  Approx. weight³  Starting starting starting method  Approx. starting start		S1) to +40°C m.a.s.l TEFC  CW and CCW) B(A) On Line	
		75% 100%	Foundation loads			
Efficiency (%) 9	95.7 96.1 95.8 96.2 9 95.8 95.5 95.9 95.6 9 0.52 0.52 0.76 0.74 (	96.2 96.3 96.2 96.3 96.3 96.2 96.3 96.2 0.83 0.82 0.86 0.86	Max. traction  Max. compression	: 6285 lb : 9499 lb		
			ntage of rated output p	nower		
Losses (%)  Bearing type	P1 (0,9;1,0) P2 (0,5;1,0) P3 (0,25;1,0) P4 (0,9;0,5) P5 (0,5;0,5) P6 (0,5;0,25) P7 (0,25;0,25)	4.5 3.3 2.7 2.5 1.5 1.1 0.6 Drive end NU-322 C3	4.4 3.2 2.6 2.5 1.5 1.0 0.6 Non driv	4.4 3.2 2.6 2.5 1.5 1.0 0.6	4.5 3.3 2.7 2.5 1.5 1.1 0.6	
Sealing Lubrication interval Lubricant amount Lubricant type	:	Inpro/Seal 4000 h 60 g	Inpro/Seal 8000 h 45 g obil Polyrex EM			
Notes:			_			

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

(1)/14/100/001/10						
Rev.	Changes Summary			Performed	Checked	Date
Performed by						
Checked by					Page	Revision
Date	25/03/2024				1/1	