## **DATA SHEET**

### Three Phase Induction Motor - Squirrel Cage



Customer	:					
Product line		Explosion ency Three		MA Premiur	m Product code : Catalog # :	11963107 25018XT3G447T
Frame Output Poles Frequency Rated voltage Rated current L. R. Amperes LRC No load current Rated speed Slip Rated torque Locked rotor torque Breakdown torque Insulation class Service factor Moment of inertia Design	•	: 447T : 250 H : 4 : 60 Hz : 460 V : 284 A : 1988 A : 7.0x(C : 90.3 A : 1784 r : 0.89 % : 736 ft. : 250 % : 250 % : F : 1.15 : 89.6 s	A Code H) A rpm 6 Ib	/)	Locked rotor time Temperature rise Duty cycle Ambient temperature Altitude Protection degree Cooling method Mounting Rotation¹ Noise level² Starting method Approx. weight³	: 36s (cold) 20s (hot) : 80 K : Cont.(S1) : -20°C to +40°C : 1000 m.a.s.l. : IP55 : IC411 - TEFC : F-1 : Both (CW and CCW) : 82.0 dB(A) : Direct On Line : 2598 lb
Output	25%	50%	75%	100%	Foundation loads	
Efficiency (%) Power Factor	95.3 95.3 0.49 0.49	95.4 95.4 0.72 0.72	95.8 95.8 0.81 0.81	96.2 95.8 95.8 95.8 0.85 0.85 0.84 0.83	Max. traction  Max. compression	: 4726 lb : 7325 lb
Bearing type Sealing Lubrication interva Lubricant amount Lubricant type		:	<u>Drive</u> 6319 Viton O 703 45	end 9 C3 Dil Seal 88 h	Non drive end 6316 C3 Viton Seal 8569 h 34 g bil Polyrex EM	

Notes:

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.

(4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.		Changes Summary	Performed	Checked	Date
Performed by					
Checked by				Page	Revision
Date	28/03/2024			1/2	

# DATA SHEET

## Three Phase Induction Motor - Squirrel Cage



_	
Customer	
Custoffici	

#### Thermal protection

l		•		
ID	Application	Туре	Quantity	Sensing Temperature
1	Winding	Thermostat - 2 wires	1 x Phase	155 °C

Rev.	Changes Summary		Performed	Checked	Date
Performed by					
Checked by				Page	Revision
Date	28/03/2024			2/2	