

# DATA SHEET

## Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W22 Tru-Metric IE3 Three-Phase

Product code : 14234122  
Catalog # : 30036ET3Y355M/L-W22

Frame	: 355M/L	Locked rotor time	: 54s (cold) 30s (hot)
Output	: 400 HP (300 kW)	Temperature rise	: 80 K
Poles	: 2	Duty cycle	: S1
Frequency	: 50 Hz	Ambient temperature	: -20°C to +40°C
Rated voltage	: 380 V	Altitude	: 1000 m.a.s.l.
Rated current	: 529 A	Protection degree	: IP55
L. R. Amperes	: 3968 A	Cooling method	: IC411 - TEFC
LRC	: 7.5	Mounting	: B3L(E)
No load current	: 85.0 A	Rotation <sup>1</sup>	: Both (CW and CCW)
Rated speed	: 2982 rpm	Noise level <sup>2</sup>	: 80.0 dB(A)
Slip	: 0.60 %	Starting method	: Direct On Line
Rated torque	: 704 ft.lb	Approx. weight <sup>3</sup>	: 4053 lb
Locked rotor torque	: 229 %		
Breakdown torque	: 240 %		
Insulation class	: F		
Service factor	: 1.15		
Moment of inertia (J)	: 143 sq.ft.lb		
Design	: N		

Output	25%	50%	75%	100%	Foundation loads				
Efficiency (%)	0.000	94.2	94.9	95.2	95.6	95.8	Max. traction : 1484 lb		
	0.000	95.3		96.1		95.8			
	0.000								
Power Factor	0.00	0.00	0.88	0.86	0.89	0.89	0.90	0.90	Max. compression : 5536 lb
	0.00		0.86		0.89		0.90		

Losses at normative operating points (speed;torque), in percentage of rated output power

Losses (%)	P1 (0,9;1,0)	4.4	4.4	4.4
	P2 (0,5;1,0)	2.7	2.7	2.7
	P3 (0,25;1,0)	1.9	1.9	1.9
	P4 (0,9;0,5)	2.9	2.9	2.9
	P5 (0,5;0,5)	1.5	1.5	1.5
	P6 (0,5;0,25)	1.2	1.2	1.2
	P7 (0,25;0,25)	0.5	0.5	0.5

		<u>Drive end</u>	<u>Non drive end</u>
Bearing type	:	6316 C3	6314 C3
Sealing	:	WSeal	WSeal
Lubrication interval	:	5000 h	7000 h
Lubricant amount	:	34 g	27 g
Lubricant type	:	Isoflex NBU-15	

Notes:

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary	Performed	Checked	Date
Performed by				
Checked by				
Date	26/03/2024			
			Page	Revision
			1 / 1	