DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W60 Three-Phase Product code : 16166782

Frame : 5010/11 Locked rotor time : 37s (cold) 21s (hot)

Output : 650 HP (480 kW) Temperature rise : 80 K

Poles Duty cycle : Cont.(S1) : 4 Frequency : 60 Hz Ambient temperature : -20°C to +40°C Rated voltage : 4160 V Altitude : 1000 m.a.s.l. Protection degree : IP24 Rated current : 81.0 A

 L. R. Amperes
 : 527 A
 Mounting
 : F-1

 LRC
 : 6.5x(Code G)
 Rotation¹
 : CW

 No load current
 : 28.2 A
 Noise level²
 : 78.0 dB(A)

Rated speed : 1783 rpm Starting method : Direct On Line Slip : 0.94 % Approx. weight³ : 4478 lb

Rated torque : 1910 ft.lb

Locked rotor torque : 200 %

Breakdown torque : 220 %

Service factor : 1.00
Moment of inertia (J) : 149 sq.ft.lb

Output 25% 50% 75% 100% Foundation loads

Efficiency (%) 94.4 94.6 95.6 95.6 Max. traction
Power Factor 0.50 0.76 0.84 0.86 Max. compression

: F

Drive endNon drive endBearing type: 6220 C36218 C3Sealing: Without Bearing SealWithout Bearing Seal

Lubrication interval:20000 h20000 hLubricant amount:31 g24 g

Lubricant amount : 31 g
Lubricant type : Mobil Polyrex EM

Notes:

Insulation class

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.

(4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary		Performed	Checked	Date
Performed by					
Checked by				Page	Revision
Date	27/03/2024			1/2	

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer	

Thermal	protection
---------	------------

ID	Application	Туре	Quantity	Sensing Temperature
1	Winding	PT100 - 3 wires	2 x Phase	-
2	DE bearing	PT100 - 3 wires	1 x Bearing	-
3	NDE bearing	PT100 - 3 wires	1 x Bearing	-

Space heater information

Voltage: 110-127/200-240 V

Rev.	Changes Summary Performed		Performed	Checked	Date
Performed by					
Checked by				Page	Revision
Date	27/03/2024			2/2	